

Type SLT Roof and Gutter Deicer

UL:
Ordinary (Unclassified) Locations

CSA:
Ordinary (Unclassified) Locations

Applications

- Nelson Type SLT heating cable provides a solution for ice dams that can build up and damage building roofs, gutters and downspouts.
- During winter months, snow and ice accumulation on roofs can prevent proper drainage of water when normal melting occurs. Water stands on the roof and can be refrozen during cold nights resulting in expansion and potential roof damage.
- Nelson's SLT ice melting heaters are designed for installation on roofs and gutters to melt a pathway for the drainage of water. The heating cable's self-regulating feature provides additional benefits as well.

Features


- Nelson SLT heating cable is a parallel circuit, self-regulating electric heater.
- An irradiated cross-linked conductive polymer core is extruded over two multi-stranded, tin-plated, 16-gauge copper buss wires. The conductive core material increases or decreases its heat output in response to temperature changes.
- A waterproof thermoplastic elastomer over jacket is then extruded over the inner jacket for dielectric protection and additional moisture resistance.
- A tinned copper braid is installed over the second jacket providing a continuous ground path.
- A flame retardant, UV stabilized polyolefin over jacket is then extruded over the braid.
- Lower Energy Consumption
 - The heater automatically reduces its power output as drainage tunnels are formed in the ice and snow.
- High Temperature Protection
 - Because the heater self regulates its power output as a function of temperature, it cannot overheat and melt or damage temperature sensitive roof coatings.

Accessories

- SLT-LPS: Power Connection Kit with Cable Seals
- SLT-RC: Roof Clips
- SLT-C: Roof Clips (Universal)
- SLT-D: Downspout Hangers
- SLT-S: Splice Kit – Heat Shrink
- SLT-E: End Termination Cable Seals – Heat Shrink
- AT-50: Aluminum Foil Tape, 50 Yards/Roll

Certifications and Compliances

- UL Listed: E33597
- CSA Standard: C22.2 No. 130-16
- CSA Certified: LR42103
- Other Standard: IEEE 515.1-2012



COMMERCIAL APPLICATIONS: ROOF AND GUTTER DEICING

NELSON™

Type SLT Roof and Gutter Deicer

UL:
Ordinary (Unclassified) Locations

CSA:
Ordinary (Unclassified) Locations

Performance and Rating Data

The total cable length for deicing is determined by including all elements of the roof system that need protection. Use the following tables to determine the total length of cable required.

Total Cable Requirements

Item	Feet of Cable/Ft. Item	Comments
Gutter	0.3 (1.0)	1 Trace/6" gutter width
Downspout	0.6 (2.0)	Unless downspout is on end of circuit, the cable is looped down and back
Roof Valley	1.8 (6.0)	Per valley
Dormer	0.3 (1.0)	1 ft. of cable/foot of dormer perimeter

Cable Footage Required for Roof Overhangs: (Feet of Cable per Foot of Roof)

Eave Overhang	Feet of Cable Loop Height	Shingle Roof	Metal Roof
0.30 (1.0)	0.46 (1.5)	0.56 (1.83)	0.76 (2.5)
0.61 (2.0)	0.76 (2.5)	0.41 (1.35)	0.76 (2.5)
0.91 (3.0)	1.07 (3.5)	0.71 (2.33)	1.07 (3.5)
1.22 (4.0)	1.37 (4.5)	1.02 (3.35)	1.37 (4.5)

COMMERCIAL APPLICATIONS: ROOF AND GUTTER DEICING

NELSON™

Type SLT Roof and Gutter Deicer

UL:
Ordinary (Unclassified) Locations

CSA:
Ordinary (Unclassified) Locations

Selection Table

Service Voltage	Power Output in Ice Watts/m (Watts/ft)	Maximum Segment Length m (ft)	Minimum Installation Temperature °C (°F)	Current Load A/m (A/ft)				Catalog Number
				-7°C (20°F) Start-Up	-18°C (0°F) Start-Up	-29°C (-20°F) Start-Up	-40°C (-40°F) Start-Up	
120	40 (12.1)	56 (185)	-37 (-35)	0.554 (0.169)	0.640 (0.195)	0.722 (0.220)	0.804 (0.245)	SLT-1
208	31 (9.5)	113 (370)	-37 (-35)	0.220 (0.067)	0.251 (0.077)	0.285 (0.087)	0.319 (0.097)	SLT-2
220	34 (10.5)	113 (370)	-37 (-35)	0.243 (0.074)	0.277 (0.084)	0.314 (0.096)	0.351 (0.107)	
240	40 (12.1)	113 (370)	-37 (-35)	0.279 (0.085)	0.318 (0.097)	0.361 (0.110)	0.404 (0.123)	
277	49 (15.0)	107 (350)	-37 (-35)	0.346 (0.105)	0.395 (0.120)	0.448 (0.136)	0.500 (0.153)	

Circuit Breaker Selection

Start-Up Temperature °C (°F)	Max. Length in Meters (Feet) Vs. Circuit Breaker Size						
	120 Vac			240 Vac			
	15A	20A	30A	15A	20A	30A	40A
-7 (20)	27 (90)	37 (120)	53 (175)	53 (175)	72 (235)	108 (355)	143 (470)
-18 (0)	23 (75)	32 (105)	47 (155)	47 (155)	62 (205)	94 (310)	125 (410)
-29 (-20)	21 (70)	27 (90)	41 (135)	41 (135)	55 (180)	84 (275)	111 (365)
-40 (-40)	18 (60)	24 (80)	37 (120)	37 (120)	50 (165)	75 (245)	99 (325)

Notes:


1. Maximum segment length is the maximum continuous heater run with minimal voltage drop. For breaker loading, multiple heater segments can be installed in parallel providing no individual length is longer than the maximum published segment length. For voltages other than 240Vac, divide full breaker amperage rating by amps/foot @ start-up temperature to determine maximum total footage allowed.
2. Circuit breakers are sized per Article 426-4 of the National Electrical Code.
3. National Electrical Codes require ground-fault equipment protection for fixed outdoor electrical deicing equipment. Electrical connections should be made by a licensed electrician.

Type SLT Roof and Gutter Deicer

UL:
Ordinary (Unclassified) Locations

CSA:
Ordinary (Unclassified) Locations

Roof, Gutter Deicer Outline



COMMERCIAL APPLICATIONS: ROOF AND GUTTER DEICING

NELSON™